

# Daily summary report

Facility: Belgrade Waste incinerator

Report time: 05/11/2024

Date of creation: 06/11/2024 00:31

Time	HCl		SO <sub>2</sub>		CO		TOC		NOx		NH <sub>3</sub>		
	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	
ELV:	60.00		ELV:	200.00		ELV:	100.00		ELV:	20.00		ELV:	400.00
00:30	VV	0.94	VV	25.47	VV	0.16	VV	0.00	VV	98.51	VV	2.02	
01:00	VV	0.95	VV	26.45	VV	0.47	VV	0.00	VV	90.43	VV	2.60	
01:30	VV	1.00	VV	28.01	VV	0.39	VV	0.00	VV	98.11	VV	2.46	
02:00	VV	0.85	VV	18.62	VV	1.26	VV	0.00	VV	84.71	VV	3.04	
02:30	VV	0.72	VV	13.55	VV	1.49	VV	0.00	VV	91.42	VV	2.72	
03:00	VV	0.70	VV	11.50	VV	1.48	VV	0.00	VV	92.62	VV	2.85	
03:30	VV	0.79	VV	16.84	VV	1.18	VV	0.00	VV	92.77	VV	2.55	
04:00	VV	0.79	VV	15.74	VV	1.38	VV	0.04	VV	95.93	VV	2.20	
04:30	VV	0.69	VV	12.33	VV	1.55	VV	0.00	VV	88.98	VV	2.53	
05:00	VV	0.73	VV	15.51	VV	1.39	VV	0.00	VV	93.36	VV	2.64	
05:30	VV	0.75	VV	14.19	VV	0.58	VV	0.00	VV	100.85	VV	1.87	
06:00	VV	0.75	VV	14.59	VV	0.92	VV	0.00	VV	92.31	VV	2.15	
06:30	VV	0.73	VV	14.35	VV	0.79	VV	0.00	VV	96.05	VV	2.11	
07:00	VV	0.72	VV	13.24	VV	0.93	VV	0.00	VV	92.26	VV	2.24	
07:30	VV	0.46	VV	13.34	VV	1.05	VV	0.02	VV	93.09	VV	2.47	
08:00	VV	0.68	VV	12.94	VV	1.03	VV	0.00	VV	98.39	VV	1.93	
08:30	VV	0.69	VV	12.15	VV	1.18	VV	0.00	VV	93.63	VV	2.16	
09:00	VV	0.89	VV	23.29	VV	1.76	VV	0.00	VV	91.83	VV	2.25	
09:30	VV	0.91	VV	20.69	VV	1.43	VV	0.00	VV	87.40	VV	2.60	
10:00	VV	0.84	VV	18.57	VV	1.10	VV	0.00	VV	89.70	VV	1.99	
10:30	VV	0.79	VV	17.97	VV	1.16	VV	0.00	VV	98.30	VV	1.99	
11:00	VV	0.73	VV	12.89	VV	1.22	VV	0.00	VV	90.95	VV	2.49	
11:30	VV	0.82	VV	18.26	VV	0.61	VV	0.00	VV	103.16	VV	2.30	
12:00	VV	0.97	VV	26.92	VV	1.16	VV	0.00	VV	86.15	VV	2.59	
12:30	VV	0.98	VV	26.09	VV	1.14	VV	0.00	VV	97.10	VV	2.59	
13:00	VV	1.02	VV	28.16	VV	0.81	VV	0.00	VV	97.16	VV	2.49	
13:30	VV	0.91	VV	25.99	VV	1.62	VV	0.00	VV	92.08	VV	2.94	
14:00	VV	0.88	VV	29.23	VV	1.94	VV	0.00	VV	93.59	VV	2.60	
14:30	VV	0.78	VV	27.35	VV	1.57	VV	0.00	VV	97.27	VV	2.64	
15:00	VV	0.80	VV	27.13	VV	1.28	VV	0.00	VV	90.19	VV	2.55	
15:30	VV	0.86	VV	27.81	VV	1.46	VV	0.00	VV	97.25	VV	2.49	
16:00	VV	0.90	VV	29.11	VV	0.39	VV	0.00	VV	100.08	VV	2.40	
16:30	VV	0.80	VV	25.12	VV	0.67	VV	0.00	VV	89.73	VV	2.67	
17:00	VV	0.78	VV	22.91	VV	1.02	VV	0.00	VV	90.60	VV	2.83	
17:30	VV	0.88	VV	25.77	VV	0.89	VV	0.00	VV	99.75	VV	2.24	
18:00	VV	0.80	VV	24.91	VV	0.82	VV	0.00	VV	92.85	VV	2.26	
18:30	VV	0.88	VV	29.08	VV	1.25	VV	0.00	VV	92.78	VV	2.34	
19:00	VV	0.86	VV	26.19	VV	1.20	VV	0.00	VV	91.13	VV	2.59	
19:30	VV	0.49	VV	28.47	VV	0.87	VV	0.00	VV	90.32	VV	2.66	
20:00	VV	0.88	VV	26.87	VV	0.58	VV	0.00	VV	102.10	VV	2.33	
20:30	VV	1.01	VV	26.53	VV	0.69	VV	0.00	VV	95.14	VV	2.17	
21:00	VV	0.90	VV	24.99	VV	0.97	VV	0.00	VV	93.94	VV	2.93	
21:30	VV	0.99	VV	29.62	VV	1.51	VV	0.00	VV	93.81	VV	2.31	
22:00	VV	0.98	VV	28.92	VV	1.09	VV	0.00	VV	95.04	VV	2.84	
22:30	VV	0.91	VV	24.98	VV	1.04	VV	0.00	VV	92.86	VV	3.36	
23:00	VV	0.92	VV	26.48	VV	1.39	VV	0.00	VV	91.44	VV	3.33	
23:30	VV	0.87	VV	25.03	VV	1.15	VV	0.00	VV	96.53	VV	3.01	
00:00	VV	0.92	VV	29.00	VV	1.34	VV	0.00	VV	91.16	VV	2.62	
DAV	V	0.83	V	22.15	V	1.09	V	0.00	V	93.85	V	2.50	
Nr. > ELV		0		0		0		0		0			
Min		0.46		11.50		0.16		0.00		84.71		1.87	
Max		1.02		29.62		1.94		0.04		103.16		3.36	

Note: The first letter refers to the plant status. The second letter refers to the measurement component status.

Plant status: V: Valid X: Not valid U: Undefined  
 Measurement status: V: Valid X: Not valid M: Maintenance F: Fault C: Out of Calibration  
 XN: Out of operation UX: Invalid operation VN: Channel not in operation  
 DAV: Day average value ELV: Emission limit value R: Replacement Value

# Daily summary report

Facility: Belgrade Waste incinerator

Report time: 05/11/2024

Date of creation: 06/11/2024 00:31

Time	HF		Hg (total)		Dust		Flow		O <sub>2</sub>		CO <sub>2</sub>	
	Unit:	mg/Nm <sup>3</sup>	Unit:	µg/Nm <sup>3</sup>	Unit:	mg/Nm <sup>3</sup>	Unit:	Nm <sup>3</sup> /h	Unit:	%	Unit:	%
	ELV:	4.00			ELV:	30.00						
00:30	VV	0.00	VV	0.33	VV	0.01	VV	212216.48	VV	8.17	VV	8.52
01:00	VV	0.00	VV	0.25	VV	0.01	VV	210806.78	VV	8.32	VV	8.47
01:30	VV	0.00	VV	0.25	VV	0.01	VV	216596.81	VV	8.16	VV	8.50
02:00	VV	0.00	VV	0.26	VV	0.01	VV	206221.71	VV	8.75	VV	8.52
02:30	VV	0.00	VV	0.25	VV	0.01	VV	208324.62	VV	8.49	VV	8.53
03:00	VV	0.00	VV	0.25	VV	0.02	VV	207425.75	VV	8.49	VV	8.53
03:30	VV	0.00	VV	0.25	VV	0.01	VV	211796.40	VV	8.26	VV	8.51
04:00	VV	0.00	VV	0.25	VV	0.01	VV	214493.19	VV	8.22	VV	8.55
04:30	VV	0.00	VV	0.25	VV	0.01	VV	209475.87	VV	8.41	VV	8.48
05:00	VV	0.00	VV	0.44	VV	0.01	VV	208789.69	VV	8.41	VV	8.52
05:30	VV	0.00	VV	0.62	VV	0.01	VV	215365.16	VV	8.11	VV	8.51
06:00	VV	0.00	VV	0.28	VV	0.01	VV	215532.35	VV	8.20	VV	8.55
06:30	VV	0.00	VV	0.25	VV	0.01	VV	216902.88	VV	8.10	VV	8.50
07:00	VV	0.00	VV	0.25	VV	0.02	VV	214693.48	VV	8.24	VV	8.53
07:30	VV	0.00	VV	0.39	VV	0.01	VV	218212.22	VV	8.07	VV	8.50
08:00	VV	0.00	VV	0.25	VV	0.01	VV	219219.30	VV	8.11	VV	8.51
08:30	VV	0.00	VV	0.37	VV	0.01	VV	214697.67	VV	8.37	VV	8.51
09:00	VV	0.00	VV	0.25	VV	0.01	VV	215671.77	VV	8.48	VV	8.46
09:30	VV	0.00	VV	0.85	VV	0.01	VV	210937.20	VV	8.49	VV	8.45
10:00	VV	0.00	VV	0.75	VV	0.01	VV	209093.11	VV	8.44	VV	8.48
10:30	VV	0.00	VV	0.41	VV	0.01	VV	215590.41	VV	8.03	VV	8.51
11:00	VV	0.00	VV	0.25	VV	0.01	VV	210624.00	VV	8.33	VV	8.50
11:30	VV	0.00	VV	0.25	VV	0.01	VV	215371.52	VV	7.96	VV	8.56
12:00	VV	0.00	VV	0.25	VV	0.01	VV	213421.92	VV	8.13	VV	8.48
12:30	VV	0.00	VV	0.25	VV	0.02	VV	212972.39	VV	8.20	VV	8.53
13:00	VV	0.00	VV	0.25	VV	0.02	VV	220614.01	VV	7.83	VV	8.55
13:30	VV	0.00	VV	0.26	VV	0.02	VV	213732.19	VV	8.42	VV	8.55
14:00	VV	0.00	VV	0.25	VV	0.01	VV	214112.17	VV	8.38	VV	8.53
14:30	VV	0.00	VV	0.25	VV	0.01	VV	217483.76	VV	8.18	VV	8.59
15:00	VV	0.00	VV	0.25	VV	0.01	VV	211587.70	VV	8.43	VV	8.50
15:30	VV	0.00	VV	0.25	VV	0.01	VV	216500.73	VV	8.16	VV	8.55
16:00	VV	0.00	VV	0.25	VV	0.01	VV	219367.19	VV	8.10	VV	8.53
16:30	VV	0.00	VV	0.32	VV	0.01	VV	211140.73	VV	8.51	VV	8.51
17:00	VV	0.00	VV	0.35	VV	0.01	VV	215335.72	VV	8.20	VV	8.54
17:30	VV	0.00	VV	0.32	VV	0.02	VV	217158.90	VV	8.18	VV	8.59
18:00	VV	0.00	VV	0.25	VV	0.01	VV	215987.50	VV	8.32	VV	8.53
18:30	VV	0.00	VV	0.25	VV	0.01	VV	215513.57	VV	8.28	VV	8.57
19:00	VV	0.00	VV	0.25	VV	0.01	VV	217673.71	VV	8.24	VV	8.48
19:30	VV	0.00	VV	0.34	VV	0.01	VV	215724.38	VV	8.33	VV	8.45
20:00	VV	0.00	VV	0.25	VV	0.01	VV	218009.06	VV	8.25	VV	8.55
20:30	VV	0.00	VV	0.25	VV	0.01	VV	218032.61	VV	8.34	VV	8.53
21:00	VV	0.00	VV	0.25	VV	0.01	VV	217319.29	VV	8.40	VV	8.54
21:30	VV	0.00	VV	0.25	VV	0.01	VV	215214.43	VV	8.48	VV	8.54
22:00	VV	0.00	VV	0.26	VV	0.01	VV	215662.76	VV	8.39	VV	8.53
22:30	VV	0.00	VV	0.26	VV	0.01	VV	211921.32	VV	8.45	VV	8.53
23:00	VV	0.00	VV	0.26	VV	0.01	VV	214105.43	VV	8.35	VV	8.49
23:30	VV	0.00	VV	0.26	VV	0.01	VV	214018.58	VV	8.32	VV	8.58
00:00	VV	0.00	VV	0.25	VV	0.01	VV	214077.37	VV	8.32	VV	8.56
DAV	V	0.00	V	0.30	V	0.01	V	214265.54	V	8.29	V	8.52
Nr. > ELV		0				0						
Min		0.00		0.25		0.01		206221.71		7.83		8.45
Max		0.00		0.85		0.02		220614.01		8.75		8.59

Note: The first letter refers to the plant status. The second letter refers to the measurement component status.

Plant status: V: Valid X: Not valid U: Undefined  
 Measurement status: V: Valid X: Not valid M: Maintenance F: Fault C: Out of Calibration  
 XN: Out of operation UX: Invalid operation VN: Channel not in operation  
 DAV: Day average value ELV: Emission limit value R: Replacement Value

# Daily summary report

Facility: Belgrade Waste incinerator

Report time: 05/11/2024

Date of creation: 06/11/2024 00:31

Time	H <sub>2</sub> O		Temp. Meas.		Abs. Press				
	Unit:	%	Unit:	°C	Unit:	mbar			
00:30	VV	17.64	VV	137.99	VV	996.79			
01:00	VV	17.32	VV	138.14	VV	996.95			
01:30	VV	17.69	VV	138.66	VV	996.95			
02:00	VV	16.57	VV	138.47	VV	997.10			
02:30	VV	17.41	VV	138.36	VV	997.06			
03:00	VV	18.21	VV	138.46	VV	997.00			
03:30	VV	18.01	VV	138.82	VV	996.94			
04:00	VV	17.84	VV	138.80	VV	997.09			
04:30	VV	17.50	VV	138.33	VV	997.12			
05:00	VV	17.58	VV	137.99	VV	997.10			
05:30	VV	18.02	VV	138.12	VV	997.04			
06:00	VV	17.88	VV	138.77	VV	997.24			
06:30	VV	18.12	VV	138.59	VV	997.45			
07:00	VV	18.41	VV	138.68	VV	997.83			
07:30	VV	18.49	VV	138.85	VV	998.02			
08:00	VV	18.35	VV	139.19	VV	998.37			
08:30	VV	17.72	VV	138.77	VV	998.38			
09:00	VV	16.46	VV	138.57	VV	998.30			
09:30	VV	17.73	VV	137.98	VV	998.31			
10:00	VV	16.87	VV	137.04	VV	998.86			
10:30	VV	17.87	VV	137.21	VV	999.08			
11:00	VV	18.41	VV	137.78	VV	999.05			
11:30	VV	20.27	VV	138.80	VV	998.69			
12:00	VV	19.85	VV	139.18	VV	998.46			
12:30	VV	19.79	VV	139.12	VV	998.58			
13:00	VV	20.58	VV	139.61	VV	998.17			
13:30	VV	19.33	VV	139.51	VV	997.73			
14:00	VV	18.24	VV	138.02	VV	997.39			
14:30	VV	17.82	VV	136.65	VV	996.98			
15:00	VV	17.45	VV	136.18	VV	996.86			
15:30	VV	18.03	VV	137.02	VV	996.51			
16:00	VV	18.13	VV	137.95	VV	996.36			
16:30	VV	17.26	VV	137.76	VV	996.39			
17:00	VV	18.23	VV	137.97	VV	996.50			
17:30	VV	18.30	VV	138.80	VV	996.63			
18:00	VV	17.70	VV	138.85	VV	996.66			
18:30	VV	17.99	VV	138.61	VV	996.65			
19:00	VV	17.73	VV	138.77	VV	996.59			
19:30	VV	17.72	VV	138.70	VV	996.62			
20:00	VV	17.95	VV	139.11	VV	996.57			
20:30	VV	18.38	VV	139.24	VV	996.58			
21:00	VV	18.04	VV	139.81	VV	996.61			
21:30	VV	17.44	VV	138.92	VV	996.65			
22:00	VV	19.24	VV	139.17	VV	996.47			
22:30	VV	19.59	VV	139.29	VV	996.30			
23:00	VV	19.54	VV	139.39	VV	996.29			
23:30	VV	19.47	VV	139.30	VV	996.50			
00:00	VV	19.25	VV	139.16	VV	996.49			
DAV	V	18.20	V	138.51	V	997.26			
Nr. > ELV									
Min		16.46		136.18		996.29			
Max		20.58		139.81		999.08			

Note: The first letter refers to the plant status. The second letter refers to the measurement component status.

Plant status: V: Valid X: Not valid U: Undefined  
 Measurement status: V: Valid X: Not valid M: Maintenance F: Fault C: Out of Calibration  
 XN: Out of operation UX: Invalid operation VN: Channel not in operation  
 DAV: Day average value ELV: Emission limit value R: Replacement Value